

Your radon questions, answered.

What is radon?	Radon is a naturally occurring radioactive gas, which is found - in some quantity - in all buildings. Exposure to high levels over a long period of time can lead to health issues.
Why test schools?	Simply to check that no children or staff are being exposed to high levels of radon gas. A similar survey carried out in 1989 found no problems at that time.
How does the test work?	A number of coaster sized plastic detectors were placed in ground floor rooms and basements for three months, before the data was analysed.
What happens if an issue is found?	Any problems found will necessitate some small scale remedial work.
Why is it happening now?	DEFA has a legal obligation to take a series of actions to limit people's exposure to radon due to recently updated health and safety legislation.
Are children at more risk than adults?	No. The general pattern is broadly similar to that in adults.
What is the harm or risk from radon?	There is compelling evidence that long-term exposure to radon can increase the risk of lung cancer.
How serious is a reading of 300 – 950 at my child's school?	Not at all serious. Radon levels vary considerably between regions and even neighbourhoods, from tens of Bq/m ³ to many thousand Bq/m ³ . In parts of England there are tens of thousand Bq/m ³ but there is no direct link between these levels and lung cancer. This is only a potential risk over many years of exposure and is exacerbated greatly in smokers (acting in synergy with the radon exposure).

Visit <https://www.ukradon.org/faq/#> for further information and frequently asked questions regarding Radon.



Report of Radon Measurements in Schools

2023

Anagh Coar Primary School
 Darragh Way, Anagh Coar
 Douglas, Isle of Man
 IM2 2BA

UKHSA id: 1586472 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476839	Headteacher/ Admin Office	27/04/2023	31/07/2023	100	140
08476862	Staffroom	27/04/2023	31/07/2023	25	34
08476826	Reception Class	27/04/2023	31/07/2023	56	76
08476818	Yr 1/2 (Wet Area Side)	27/04/2023	31/07/2023	72	99
08476817	Yr 1/2 (Teaching Class Side)	27/04/2023	31/07/2023	97	130
08476859	Yr 4/5	27/04/2023	31/07/2023	36	49
08476851	Yr 6	27/04/2023	31/07/2023	48	66
08476895	Position 8	27/04/2023	31/07/2023	68	93

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Andreas School
 Andreas Village
 Ramsey, Isle of Man
 IM7 4EZ

UKHSA id: 1586494 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476198	Reception	27/04/2023	19/07/2023	50	64
08476291	Yr 1/2	27/04/2023	19/07/2023	41	53
08476292	Yr 3/4	27/04/2023	19/07/2023	42	53
08476271	Yr 5/6	27/04/2023	19/07/2023	41	53
08476254	Shared Area	27/04/2023	19/07/2023	40	51
08476217	Office	27/04/2023	19/07/2023	40	51
08476233	Office	27/04/2023	19/07/2023	22	28
08476264	Learning Lounge	27/04/2023	19/07/2023	34	44

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Arbory School
Ballabeg
Isle of Man
IM9 4LH

UKHSA id: 1586501 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476445	Office	27/04/2023	25/09/2023	53	73
08476492	Desk	27/04/2023	25/09/2023	47	66
08476407	Staff Room	27/04/2023	25/09/2023	82	110
08476461	Projector Screen Yr 6	27/04/2023		N/R	N/R
08476440	J.A. Office	27/04/2023	25/09/2023	71	99
08476480	Alcove Yr 1	27/04/2023	25/09/2023	51	71
08476458	Room	27/04/2023	25/09/2023	16	23
08476499	Shared Area	27/04/2023	25/09/2023	28	39

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Ashley Hill Primary School
 Onchan
 Isle of Man
 IM3 3LA

UKHSA id: 1586480 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476097	R154	27/04/2023	04/10/2023	30	42
08476072	R142	27/04/2023	04/10/2023	19	26
08476087	R139	27/04/2023	04/10/2023	71	99
08476058	R163	27/04/2023	04/10/2023	29	40
08476017	R125	27/04/2023	04/10/2023	10	14
08476016	R123	27/04/2023	04/10/2023	16	22
08476024	R102	27/04/2023	04/10/2023	<10	13
08476011	R109	27/04/2023	04/10/2023	11	15

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Ballacottier Primary School
 Clybane Road, Farmhill
 Braddan, Isle of Man
 IM2 2ST

UKHSA id: 1586473 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476811	Position 1	27/04/2023	01/08/2023	67	92
08476842	Position 2	27/04/2023	01/08/2023	190	270
08476831	Position 3	27/04/2023	01/08/2023	120	160
08476857	Position 4	27/04/2023	01/08/2023	32	44
08476888	Position 5	27/04/2023		N/R	N/R
08476864	Position 6	27/04/2023	01/08/2023	190	260
08476860	Position 7	27/04/2023	01/08/2023	63	86
08476837	Position 8	27/04/2023		N/R	N/R

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Ballakermeen High School
 St Catherine's Drive
 Douglas, Isle of Man
 IM1 4BE

UKHSA id: 1586467

UKHSA Batch: OCC1901

Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476324	Fitness Suite	27/04/2023	01/08/2023	16	22
08476400	ILB	27/04/2023	01/08/2023	21	28
08476386	M6 M Block	27/04/2023	01/08/2023	17	23
08476317	H2 Art	27/04/2023	01/08/2023	43	58
08476362	K1	27/04/2023	01/08/2023	16	22
08476335	D1 M Block	27/04/2023	01/08/2023	<10	<10
08476352	H7	27/04/2023	01/08/2023	22	30
08476374	D4 M Block	27/04/2023	01/08/2023	25	34
08476344	Y3	27/04/2023	01/08/2023	11	15
08476399	K6	27/04/2023	01/08/2023	25	34
08476321	Staffroom	27/04/2023	01/08/2023	24	33
08476393	Studio	27/04/2023	01/08/2023	28	38
08476322	D8 M Block	27/04/2023	01/08/2023	29	40
08476312	H3	27/04/2023	01/08/2023	21	29
08476327	D6 M Block	27/04/2023	01/08/2023	23	31
08476356	M4 M Block	27/04/2023	01/08/2023	39	53
08476329	H8	27/04/2023	01/08/2023	15	21
08476332	K3	27/04/2023	01/08/2023	18	25
08476349	K5	27/04/2023	01/08/2023	47	64
08476310	Y1	27/04/2023	01/08/2023	23	32
08476368	K9	27/04/2023	01/08/2023	18	24
08476353	Y6	27/04/2023	01/08/2023	<10	11
08476375	L8	27/04/2023	01/08/2023	42	57
08476338	M1	27/04/2023	01/08/2023	36	50
08476355	P4	27/04/2023	01/08/2023	22	30

08476357	P7	27/04/2023	01/08/2023	35	48
08476311	P1	27/04/2023	01/08/2023	31	43
08476315	R1 C Block	27/04/2023	01/08/2023	45	62
08476358	Red Common Room	27/04/2023	01/08/2023	20	27
08476328	P2	27/04/2023	01/08/2023	25	35
08476336	EAL	27/04/2023	01/08/2023	40	54
08476351	Pool Side	27/04/2023	01/08/2023	12	16
08476346	Sports Hall	27/04/2023	01/08/2023	26	36
08476392	T1 Mobile	27/04/2023	01/08/2023	<10	<10
08476309	R8 C Block	27/04/2023	01/08/2023	57	78
08476314	L6	27/04/2023	01/08/2023	13	18
08476372	S1	27/04/2023	01/08/2023	22	30
08476383	S6	27/04/2023	01/08/2023	13	18
08476316	L2	27/04/2023	01/08/2023	21	29
08476323	C7	27/04/2023	01/08/2023	25	35
08476313	C1	27/04/2023	01/08/2023	24	33
08476325	C10	27/04/2023	01/08/2023	<10	<10
08476319	Special Unit	27/04/2023	01/08/2023	33	46
08476307	B4 Drama	27/04/2023	01/08/2023	71	97
08476334	Library	27/04/2023	01/08/2023	30	41

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Ballasalla School
 Ballasalla
 Isle of Man
 IM9 2LA

UKHSA id: 1586500 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476496	Administration Office	27/04/2023	08/08/2023	73	100
08476450	Hazel Class	27/04/2023	08/08/2023	59	81
08476439	Head Office	27/04/2023	08/08/2023	62	85
08476423	Hawthorns Class	27/04/2023	08/08/2023	85	120
08476447	PPA Room	27/04/2023	08/08/2023	95	130
08476442	Staff Room	27/04/2023	08/08/2023	190	260
08476409	Fuchsia Class	27/04/2023	08/08/2023	82	110
08476489	Hall	27/04/2023	08/08/2023	66	91

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Ballaugh School
 Station Road
 Ballaugh, Isle of Man
 IM7 5AH

UKHSA id: 1586495 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476266	Class 3	27/04/2023	31/07/2023	94	130
08476300	Front Office	27/04/2023	31/07/2023	100	140
08476247	Hall	27/04/2023	31/07/2023	55	76
08476218	Reception	27/04/2023	31/07/2023	140	200
08476203	Class 4	27/04/2023	31/07/2023	110	150
08476219	Mobile Classroom	27/04/2023	31/07/2023	12	17
08476255	Staffroom	27/04/2023	31/07/2023	50	68
08476237	Shared Area	27/04/2023	31/07/2023	100	140

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Braddan School
 Braddan
 Isle of Man
 IM4 4TQ

UKHSA id: 1586486 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476184	Year 4 Class	27/04/2023	19/07/2023	59	80
08476183	Year 3	27/04/2023	19/07/2023	52	71
08476125	Year 6	27/04/2023	19/07/2023	59	80
08476148	Main Hall	27/04/2023	19/07/2023	68	93
08476192	Recp Wet Area KS1	27/04/2023	19/07/2023	78	110
08476167	Year 1	27/04/2023	19/07/2023	120	170
08476159	Dining Hall	27/04/2023		N/R	N/R
08476149	Year 5 Class	27/04/2023	19/07/2023	82	110

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Bunscoil Ghaelgagh
Main Road
St John's, Isle of Man
IM4 3NA

UKHSA id: 1586483 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476091	School Hall	27/04/2023	01/08/2023	140	190
08476094	Chamyr Skimmer Staffroom	27/04/2023		N/R	N/R
08476023	Brastyl 2	27/04/2023	01/08/2023	83	110
08476057	Chamyr Gial	27/04/2023		N/R	N/R
08476066	Brastyl 1	27/04/2023		N/R	N/R
08476021	School Office	27/04/2023	01/08/2023	100	140
08476043	Mobile Classroom	27/04/2023	01/08/2023	<10	11
08476051	Brastyl Barrule 3	27/04/2023	01/08/2023	110	150

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Bunscoill Rhumsaa
 Lezayre Raod
 Ramsey, Isle of Man
 IM8 2PA

UKHSA id: 1586496

UKHSA Batch: OCC1901

Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476294	Head's Office (Infants)	27/04/2023	21/07/2023	130	180
08476275	Y3 AQ Classroom	27/04/2023	21/07/2023	100	140
08476226	Infant Staffroom	27/04/2023	21/07/2023	78	110
08476250	Blueroom	27/04/2023	21/07/2023	210	290
08476245	Y5 Classroom	27/04/2023	21/07/2023	53	72
08476220	Staffroom	27/04/2023	21/07/2023	48	66
08476295	Reception F7 Classroom	27/04/2023	21/07/2023	81	110
08476243	HT Office (Junior)	27/04/2023	21/07/2023	120	170

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Castle Rushen High School
 Arbory Road
 Castletown, Isle of Man
 IM9 1RE

UKHSA id: 1586499

UKHSA Batch: OCC1901

Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476205	Rm 14	27/04/2023	03/08/2023	21	27
08476280	Rm 13	27/04/2023	03/08/2023	15	19
08476241	Rm 12	27/04/2023	03/08/2023	10	13
08476246	Rm 11	27/04/2023	03/08/2023	20	26
08476234	Rm 10	27/04/2023	03/08/2023	23	29
08476244	DT 1	27/04/2023	03/08/2023	14	18
08476206	DT 2	27/04/2023	03/08/2023	33	42
08476212	Art 3	27/04/2023	03/08/2023	11	14
08476238	Art 2	27/04/2023	03/08/2023	18	23
08476251	DT 3	27/04/2023	03/08/2023	29	37
08476240	DT 4	27/04/2023	03/08/2023	20	26
08476278	Rm 9	27/04/2023	03/08/2023	43	55
08476270	Rm 8	27/04/2023	03/08/2023	37	47
08476284	Rm 7	27/04/2023	03/08/2023	32	41
08476253	Rm 6	27/04/2023	03/08/2023	36	46
08476298	Music 2	27/04/2023	03/08/2023	49	63
08476235	Music 1	27/04/2023	03/08/2023	73	94
08476289	Rm 5	27/04/2023	03/08/2023	80	110
08476228	Rm 4	27/04/2023	03/08/2023	41	56
08476232	Rm 3	27/04/2023	03/08/2023	32	44
08476223	Rm 1	27/04/2023	03/08/2023	28	39
08476222	Rm 2	27/04/2023	03/08/2023	43	59
08476260	H 10	27/04/2023		N/R	N/R
08476276	H 9	27/04/2023	03/08/2023	56	77
08476216	H 1	27/04/2023	03/08/2023	37	50

08476242	H 2	27/04/2023	03/08/2023	52	72
08476261	H 8	27/04/2023	03/08/2023	66	90
08476227	Hum Office	27/04/2023	03/08/2023	77	110
08476462	H 7	27/04/2023	03/08/2023	12	16
08476475	H 6	27/04/2023	03/08/2023	14	19
08476493	Skills 3	27/04/2023		N/R	N/R
08476459	Skills 1	27/04/2023	03/08/2023	48	65
08476457	F 1	27/04/2023	03/08/2023	48	65
08476427	F 2	27/04/2023	03/08/2023	41	56
08476471	F 3	27/04/2023	03/08/2023	38	52
08476464	F 4	27/04/2023	03/08/2023	37	51
08476434	C 1	27/04/2023	03/08/2023	46	63
08476491	C 2	27/04/2023	03/08/2023	50	69
08476435	C 3	27/04/2023	03/08/2023	45	61
08476460	C 4	27/04/2023	03/08/2023	25	34

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Cronk y Berry School
Hailwood Avenue
Douglas, Isle of Man
IM2 7PA

UKHSA id: 1586479 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476036	Yr 6 (FC) Lower Floor	27/04/2023	18/07/2023	30	38
08476062	Yr 5 (BM) Lower Floor	27/04/2023	18/07/2023	22	28
08476086	Middle Floor Changing Room	27/04/2023	18/07/2023	55	70
08476070	Sports Hall	27/04/2023	18/07/2023	26	34
08476085	Reception	27/04/2023	18/07/2023	54	69
08476074	Sunshine Room	27/04/2023	18/07/2023	26	34
08476088	Intervention Room (Top Floor)	27/04/2023	18/07/2023	68	88
08476012	Main Foyer	27/04/2023	18/07/2023	31	39

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Dhoon School
 Glen Mona
 Maughold, Isle of Man
 IM7 1HA

UKHSA id: 1586491 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476188	Senior Leadership Office	27/04/2023	13/09/2023	16	23
08476176	Administrator Office	27/04/2023	13/09/2023	14	20
08476160	Staff Room	27/04/2023	13/09/2023	16	22
08476154	Entrance Area	27/04/2023	13/09/2023	16	23
08476169	PPA Room	27/04/2023	13/09/2023	35	49
08476145	School Hall	27/04/2023	13/09/2023	30	42
08476139	Caretaker Room	27/04/2023	13/09/2023	27	38
08476197	Library	27/04/2023	13/09/2023	12	17

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Foxdale School
 Mines Road
 Higher Foxdale, Isle of Man
 IM4 3EX

UKHSA id: 1586482 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476001	Position 1	27/04/2023		N/R	N/R
08476026	Position 2	27/04/2023		N/R	N/R
08476033	Position 3	27/04/2023	19/07/2023	52	67
08476090	Position 4	27/04/2023	19/07/2023	27	34
08476065	Position 5	27/04/2023	19/07/2023	32	41
08476049	Position 6	27/04/2023	19/07/2023	56	71
08476067	Position 7	27/04/2023	19/07/2023	43	55
08476084	Position 8	27/04/2023	19/07/2023	24	31

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Henry Bloom Noble Primary School
Westmoreland Road
Douglas, Isle of Man
IM1 4QD

UKHSA id: 1586466 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476380	Reception Area	27/04/2023		N/R	N/R
08476301	1W Classroom	27/04/2023	18/07/2023	41	53
08476333	2S Classroom	27/04/2023	18/07/2023	30	38
08476306	Butterfly Classroom	27/04/2023	18/07/2023	88	110
08476381	Staffroom	27/04/2023		N/R	N/R
08476305	Boiler Room	27/04/2023	18/07/2023	<10	13
08476373	Hall	27/04/2023	18/07/2023	28	36
08476341	Kitchen	27/04/2023	18/07/2023	25	32

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Jurby Community School
 School Close
 Jurby, Isle of Man
 IM7 3BJ

UKHSA id: 1586493 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476173	Head's Office	27/04/2023	31/07/2023	46	63
08476177	Admin Office	27/04/2023	31/07/2023	61	83
08476162	Staff Room	27/04/2023	31/07/2023	110	160
08476161	Main Hall	27/04/2023	31/07/2023	71	97
08476114	Class 3	27/04/2023	31/07/2023	30	42
08476121	Class 2	27/04/2023	31/07/2023	44	61
08476165	Class 1	27/04/2023	31/07/2023	21	28
08476158	ClassRoom	27/04/2023	31/07/2023	56	76

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Kewaigue School
 Kewaigue Hill
 Douglas, Isle of Man
 IM2 1QH

UKHSA id: 1586471 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476815	Main Entrance	27/04/2023	09/08/2023	91	120
08476867	year 4/5 Classroom	27/04/2023	09/08/2023	370	500
08476802	Staffroom	27/04/2023	09/08/2023	160	220
08476836	Library	27/04/2023	09/08/2023	150	200
08476816	Hall	27/04/2023	09/08/2023	82	110
08476808	Boiler Room	27/04/2023	09/08/2023	110	150
08476838	Year 3 Classroom	27/04/2023	09/08/2023	<10	<10
08476855	Year 6 Classroom	27/04/2023	09/08/2023	<10	12

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Laxey School
 Quarry Road
 Laxey, Isle of Man
 IM4 7DU

UKHSA id: 1586487 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476132	Corridor Above Reception	27/04/2023	04/10/2023	120	160
08476126	KS1 Middle Area	27/04/2023	04/10/2023	60	82
08476116	Youth Den	27/04/2023	04/10/2023	47	64
08476190	TLR Office	27/04/2023	04/10/2023	41	56
08476108	The Hub	27/04/2023	04/10/2023	180	240
08476147	EHT Office	27/04/2023	04/10/2023	43	59
08476118	Staff Room	27/04/2023	04/10/2023	76	100
08476191	Y3 Class	27/04/2023	04/10/2023	36	50

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Manor Park Primary School
 Pulrose Road
 Douglas, Isle of Man
 IM2 1AT

UKHSA id: 1586468 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476337	Hall	27/04/2023	31/07/2023	58	79
08476369	Rowan Class	27/04/2023		N/R	N/R
08476397	Mighty Oak Class	27/04/2023	31/07/2023	32	44
08476391	Home Chestnut Class	27/04/2023	31/07/2023	36	49
08476398	Old Rowan Class	27/04/2023	31/07/2023	37	51
08476303	Reading Area	27/04/2023	31/07/2023	48	66
08476302	Willow Class	27/04/2023	31/07/2023	40	54
08476340	Staffroom	27/04/2023	31/07/2023	31	42

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Marown Primary School
 Glen Darragh Raod
 Glen Vine, Isle of Man
 IM4 4RD

UKHSA id: 1586485 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476068	Reception Class	27/04/2023	31/07/2023	170	240
08476082	Class 1	27/04/2023	31/07/2023	180	240
08476095	Class 2	27/04/2023	31/07/2023	190	250
08476099	Class 3	27/04/2023	31/07/2023	180	250
08476063	Staff Room	27/04/2023	31/07/2023	110	150
08476041	Class 4	27/04/2023	31/07/2023	160	220
08476073	Class 5	27/04/2023	31/07/2023	150	200
08476020	Class 6	27/04/2023	31/07/2023	96	130

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Michael School
Main Road
Kirk Michael, Isle of Man
IM6 1AJ

UKHSA id: 1586490 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476124	Staff Room	27/04/2023	21/07/2023	90	120
08476194	Fuchsia Class	27/04/2023	21/07/2023	73	94
08476195	Orchid Classroom	27/04/2023	21/07/2023	89	110
08476171	Bluebell Classroom	27/04/2023	21/07/2023	49	63
08476115	Daffodil Classroom	27/04/2023	21/07/2023	41	53
08476112	Poppy Classroom	27/04/2023	21/07/2023	39	50
08476134	Daisy Classroom	27/04/2023	21/07/2023	73	94
08476163	Dining Room	27/04/2023	21/07/2023	38	48

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Onchan School
 School Road
 Onchan, Isle of Man
 IM3 4PD

UKHSA id: 1586481 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476008	PPA Room	27/04/2023	31/07/2023	120	160
08476092	Foundation	27/04/2023	31/07/2023	60	82
08476064	Y3	27/04/2023	31/07/2023	44	61
08476081	KS1	27/04/2023	31/07/2023	28	38
08476014	Headteacher	27/04/2023	31/07/2023	53	73
08476015	Classroom	27/04/2023		N/R	N/R
08476030	Staff Room	27/04/2023	31/07/2023	49	66
08476010	School Office	27/04/2023	31/07/2023	56	77

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Peel Clothworkers

The results from the radon surveys are currently unavailable.

A resurvey of the school will take place and the results will be published once they are available in approximately 12 weeks.

Queen Elizabeth II High School
 Douglas Road
 Peel, Isle of Man
 IM5 1RD

UKHSA id: 1586489

UKHSA Batch: OCC1901

Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476119	Room 6	27/04/2023	23/08/2023	77	110
08476156	Room 5	27/04/2023	23/08/2023	18	25
08476141	Room 14	27/04/2023	23/08/2023	38	52
08476196	Lab Room 31	27/04/2023	23/08/2023	43	58
08476117	Canteen	27/04/2023	23/08/2023	28	39
08476104	Room 7	27/04/2023	23/08/2023	67	92
08476187	Assembly Hall	27/04/2023	23/08/2023	28	39
08476120	Site Staff	27/04/2023	23/08/2023	15	20
08476129	S4L Main Room	27/04/2023	23/08/2023	36	50
08476182	Staff Room	27/04/2023	23/08/2023	26	36
08476153	Room 29	27/04/2023	23/08/2023	59	80
08476142	Library	27/04/2023	23/08/2023	56	76
08476113	Room 10	27/04/2023	23/08/2023	120	160
08476131	Special Need Revision Centre	27/04/2023		N/R	N/R
08476180	Basement Room 57	27/04/2023	23/08/2023	110	150
08476135	Main Entrance	27/04/2023	23/08/2023	<10	<10
08476111	Main Office Reception 2	27/04/2023	23/08/2023	34	46
08476185	Room 8	27/04/2023	23/08/2023	52	71
08476152	Room 9	27/04/2023	23/08/2023	74	100
08476144	SPC Back Room	27/04/2023	23/08/2023	63	86
08476199	Room 21	27/04/2023	23/08/2023	71	97
08476128	Room F13	27/04/2023	23/08/2023	32	44
08476138	Sport Hall	27/04/2023		N/R	N/R
08476102	Room 20	27/04/2023	23/08/2023	71	97
08476143	Room 32 Textile	27/04/2023	23/08/2023	64	88

08476106	Room 26	27/04/2023	23/08/2023	53	72
08476105	Room F15	27/04/2023	23/08/2023	15	20
08476107	Room 25	27/04/2023	23/08/2023	69	94
08476146	Common Room	27/04/2023	23/08/2023	21	29
08476151	Atrium Hall	27/04/2023	23/08/2023	43	59
08476136	D13	27/04/2023	23/08/2023	150	200
08476155	Exam Office	27/04/2023	23/08/2023	22	30
08476122	Room F12	27/04/2023		N/R	N/R
08476123	Room 30	27/04/2023	23/08/2023	22	31
08476178	D06	27/04/2023	23/08/2023	48	66
08476175	D16	27/04/2023	23/08/2023	170	230
08476179	Entrance Kitchen	27/04/2023	23/08/2023	39	53
08476164	Room 23	27/04/2023	23/08/2023	50	69
08476186	Room 22	27/04/2023	23/08/2023	41	56
08476101	Room 33 Food	27/04/2023	23/08/2023	100	140

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Ramsey Grammar School
Lezayre Raod
Ramsey, Isle of Man
IM8 2RG

UKHSA id: 1586497 UKHSA Batch: OCC1901		Client building ref:			
Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476282	West Room 201	27/04/2023	18/09/2023	16	23
08476230	West Reprographics	27/04/2023	18/09/2023	17	24
08476263	West Staffroom	27/04/2023	18/09/2023	23	32
08476224	West Room 111	27/04/2023	18/09/2023	13	19
08476262	West Room 177	27/04/2023	18/09/2023	<10	<10
08476239	West Library	27/04/2023	18/09/2023	87	120
08476211	West Room 206	27/04/2023	18/09/2023	25	36
08476252	West Room 108	27/04/2023	18/09/2023	15	22
08476236	West Room 105	27/04/2023	18/09/2023	15	22
08476249	West Room 103	27/04/2023	18/09/2023	12	17
08476201	West Dining Hall	27/04/2023	18/09/2023	33	46
08476293	West Hall	27/04/2023	18/09/2023	61	85
08476214	West Room 204	27/04/2023	18/09/2023	33	47
08476225	South Room 152	27/04/2023	18/09/2023	50	70
08476213	South Room 151	27/04/2023	18/09/2023	76	110
08476286	South Room 155	27/04/2023	18/09/2023	43	61
08476189	South Room 173	27/04/2023	18/09/2023	69	97
08476297	South Room 171	27/04/2023	18/09/2023	17	24
08476231	South Room 175	27/04/2023	18/09/2023	11	15
08476273	South ISC 2	27/04/2023	18/09/2023	77	110
08476202	South Art 272	27/04/2023	18/09/2023	14	20
08476274	South Social Science Office	27/04/2023	18/09/2023	43	61
08476210	South Hector Duff Centre	27/04/2023	18/09/2023	22	32
08476277	South Lecture Theatre	27/04/2023	18/09/2023	31	43
08476269	East Hall	27/04/2023	18/09/2023	25	36

08476296	East Gym	27/04/2023	18/09/2023	18	26
08476258	East Foyer	27/04/2023	18/09/2023	42	59
08476281	East Room 11	27/04/2023	18/09/2023	90	130
08476283	East Room 20	27/04/2023	18/09/2023	83	120
08476204	East Room 16	27/04/2023	18/09/2023	100	150
08476279	East Room 14	27/04/2023	18/09/2023	55	77
08476290	East Lab 2	27/04/2023	18/09/2023	45	63
08476207	East Lab 4	27/04/2023	18/09/2023	18	25
08476287	East Lab 7	27/04/2023	18/09/2023	21	29
08476267	East Lab 9	27/04/2023	18/09/2023	17	24
08476288	Sports Hall Downstairs Gym	27/04/2023	18/09/2023	12	17
08476265	Sports Hall Female Staff Room	27/04/2023	18/09/2023	13	19
08476268	Sports Hall Main Hall	27/04/2023	18/09/2023	29	41
08476221	Sports Hall Upstairs Gym	27/04/2023	18/09/2023	27	37
08476208	Sports Hall Upstairs Classroom	27/04/2023	18/09/2023	16	22

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Rushen Primary School
Church Road
Port St Mary, Isle of Man
IM9 5LW

UKHSA id:	1586502	UKHSA Batch:	OCC1901	Client building ref:		
Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³	
08476482	Position 1	27/04/2023	26/09/2023	56	78	
08476454	Position 2	27/04/2023		N/R	N/R	
08476410	Position 3	27/04/2023	26/09/2023	94	130	
08476403	Position 4	27/04/2023	26/09/2023	97	130	
08476417	Position 5	27/04/2023	26/09/2023	120	170	
08476456	Position 6	27/04/2023	26/09/2023	56	78	
08476446	Position 7	27/04/2023	26/09/2023	98	140	
08476449	Position 8	27/04/2023	26/09/2023	100	140	

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

There is no result available for the monitor listed as N/R because it was not returned by the customer.

Scoill Phurt le Moirrey
 Station Road
 Port St Mary, Isle of Man
 IM9 5RB

UKHSA id: 1586503 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476405	Front Lobby	27/04/2023	08/08/2023	140	190
08476431	Outside Classroom 1	27/04/2023	08/08/2023	140	190
08476498	Infant Shared Area	27/04/2023	08/08/2023	130	180
08476422	Assembly Hall	27/04/2023	08/08/2023	150	200
08476404	Outside Classroom 5	27/04/2023	08/08/2023	130	170
08476488	Outside Classroom 7	27/04/2023	08/08/2023	130	170
08476428	Staffroom	27/04/2023	08/08/2023	130	180
08476453	Dining Room	27/04/2023	08/08/2023	120	170

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Scoill Vallajeelt
Meadow Crescent
Douglas, Isle of Man
IM2 1NN

UKHSA id: 1586469

UKHSA Batch: OCC1901

Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476331	Y1	27/04/2023	01/08/2023	92	130
08476354	Y2	27/04/2023	01/08/2023	110	150
08476342	Reception	27/04/2023	01/08/2023	100	140
08476345	Boiler Room	27/04/2023	01/08/2023	<10	<10
08476308	Y5	27/04/2023	01/08/2023	73	100
08476360	Y6	27/04/2023	01/08/2023	75	100
08476394	Staffroom	27/04/2023	01/08/2023	240	330
08476339	Caretakers Office	27/04/2023	01/08/2023	700	950

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Scoill yn Jubilee Primary School
 Stoney Road
 Douglas, Isle of Man
 IM2 3BR

UKHSA id: 1586474 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476893	Position 1	27/04/2023	03/08/2023	28	39
08476832	Position 2	27/04/2023	03/08/2023	58	79
08476810	Position 3	27/04/2023	03/08/2023	33	46
08476868	Position 4	27/04/2023	03/08/2023	31	43
08476873	Position 5	27/04/2023	03/08/2023	17	23
08476869	Position 6	27/04/2023	03/08/2023	10	14
08476896	Position 7	27/04/2023	03/08/2023	18	25
08476809	Position 8	27/04/2023	03/08/2023	12	16

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

St John's School
 Station Road
 St John's, Isle of Man
 IM4 3RD

UKHSA id: 1586484 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476038	Main School Entrance	27/04/2023	11/09/2023	310	440
08476100	Key Stage 1 Corridor	27/04/2023	11/09/2023	290	410
08476013	Key Stage 1 Wet Area	27/04/2023	11/09/2023	230	320
08476009	Key Stage 2 Wet Area	27/04/2023	11/09/2023	230	330
08476028	Key Stage 2 Corridor	27/04/2023	11/09/2023	240	340
08476054	Assembly Hall	27/04/2023	11/09/2023	99	140
08476018	Sport Hall	27/04/2023	11/09/2023	79	110
08476083	Youth Club	27/04/2023	11/09/2023	88	120

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

St Mary's RC School
 St Mary's Road
 Douglas, Isle of Man
 IM2 5RB

UKHSA id: 1586476

UKHSA Batch: OCC1901

Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476882	Caretaker Office	27/04/2023	21/07/2023	27	36
08476830	Music Room	27/04/2023	21/07/2023	29	40
08476878	Staff Room	27/04/2023	21/07/2023	55	75
08476844	1/2 Mr Classroom	27/04/2023	21/07/2023	28	38
08476866	1/2 BM Classroom	27/04/2023		N/R	N/R
08476834	Reception NL	27/04/2023	21/07/2023	17	23
08476850	Hall	27/04/2023	21/07/2023	23	32
08476804	Reception CW	27/04/2023	21/07/2023	<10	<10

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

St Ninian's High School
 Ballaquayle Road
 Douglas, Isle of Man
 IM2 5RA

UKHSA id: 1586475 UKHSA Batch: OCC1901

Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476845	Site Managers Office	27/04/2023	10/08/2023	60	83
08476881	Premises Staff Room	27/04/2023	10/08/2023	14	19
08476812	Premises Work Kitchen	27/04/2023	10/08/2023	17	23
08476852	Black Hole LGF Large Room 2m Rear Door	27/04/2023	10/08/2023	34	46
08476805	Black Hole LGF Large Room Shelf	27/04/2023	10/08/2023	38	52
08476814	LGF Drama Room	27/04/2023	10/08/2023	24	33
08476872	LGF Bay Changing Room	27/04/2023	10/08/2023	56	77
08476856	Progress Zone Main Area	27/04/2023		N/R	N/R
08476889	Lower Canteen Store Room	27/04/2023	10/08/2023	45	61
08476828	Main Office	27/04/2023	10/08/2023	100	140
08476890	Blue Corridor Store Room	27/04/2023	10/08/2023	88	120
08476877	Store Room Work Area	27/04/2023	10/08/2023	20	28
08476898	CAB 9 Room	27/04/2023	10/08/2023	310	430
08476825	LGF Under Stair Unit	27/04/2023	10/08/2023	37	51
08476846	DT Technicians Work/Store Area	27/04/2023	10/08/2023	49	67
08476897	6th Form Office	27/04/2023	10/08/2023	18	25
08476821	Store Room (Formerly Position 17)	27/04/2023	10/08/2023	670	910
08476820	Inventory Office	27/04/2023		N/R	N/R
08476835	Centre Garden Large Storage Area	27/04/2023	10/08/2023	17	24
08476813	DT Technicians Office	27/04/2023	10/08/2023	38	52
08476892	Position 21	27/04/2023	10/08/2023	79	110
08476807	Store Room	27/04/2023	10/08/2023	160	220
08476819	J128E - Garage	27/04/2023	10/08/2023	55	75
08476858	J129E - Sport Equipment Store	27/04/2023	10/08/2023	27	37
08476806	Kitchen Storage	27/04/2023	10/08/2023	31	43

08476853	E100S - Door - Cleaners Cupboard	27/04/2023	10/08/2023	77	110
08476849	Electric Cupboard	27/04/2023	10/08/2023	52	71
08476827	Door - P107	27/04/2023	10/08/2023	61	83
08476847	Wall By Fire Exit	27/04/2023	10/08/2023	88	120
08476875	Cabling On Wall	27/04/2023	10/08/2023	61	83
08476884	Wall By Pump System	27/04/2023	10/08/2023	33	46
08476803	Wall By BT Box	27/04/2023	10/08/2023	19	27
08476880	H111 - Cleaners Store Room	27/04/2023	10/08/2023	35	48
08476801	L110 - Door - Shelf Unit	27/04/2023	10/08/2023	96	130
08476824	H113 PE Electric Cupboard	27/04/2023	10/08/2023	69	94
08476823	Cleaners Cupboard Yellow Box	27/04/2023	10/08/2023	31	42
08476886	Main Gas Valve Switch in Plant Room	27/04/2023	10/08/2023	<10	14
08476841	Gas Valve A in Plant Room	27/04/2023	10/08/2023	14	20
08476900	J110P CCTV Area	27/04/2023	10/08/2023	520	720
08476840	Cleaners Cupboard Switchboard	27/04/2023	10/08/2023	250	350
08476891	DT Technicians Office	27/04/2023	10/08/2023	190	260
08476879	Store Room (Formerly Position 42)	27/04/2023	10/08/2023	<10	10
08476874	Electrical Cupboard By Lift	27/04/2023	10/08/2023	51	70
08476887	Cleaners Cupboard Top Of Yellow Box	27/04/2023	10/08/2023	34	47
08476833	J126S Cleaners Storeroom	27/04/2023	10/08/2023	150	200

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

St Thomas' C of E Primary School
Meadow Campus, Meadow Crescent
Douglas, Isle of Man
IM2 1NN

UKHSA id: 1586470 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476370	Front Entrance	27/04/2023	31/07/2023	150	200
08476348	Dome	27/04/2023	31/07/2023	88	120
08476861	Staff Room	27/04/2023	31/07/2023	270	360
08476899	Reception Class	27/04/2023	31/07/2023	120	160
08476865	Yr 1/2	27/04/2023	31/07/2023	110	140
08476863	Yr 5/6	27/04/2023	31/07/2023	60	83
08476822	Yr 3/4	27/04/2023	31/07/2023	65	89
08476854	Photo Copy room	27/04/2023	31/07/2023	110	140

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

Sulby Primary School
Main Road
Sulby, Isle of Man
IM7 2HP

UKHSA id: 1586492 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476170	Main Corridor	27/04/2023	24/07/2023	36	50
08476166	Main Entrance	27/04/2023	24/07/2023	14	19
08476174	Year 3 Classroom	27/04/2023	24/07/2023	16	21
08476140	Reception Class Corridor	27/04/2023	24/07/2023	31	43
08476200	Year 6 Calassroom	27/04/2023	24/07/2023	21	29
08476103	Year 1 Classroom	27/04/2023	24/07/2023	31	42
08476172	Position 7	27/04/2023	24/07/2023	40	55
08476150	Shared Area Key Stage 2	27/04/2023	24/07/2023	12	16

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

University College Isle of Man (UCM)
 Homefield Road
 Douglas, Isle of Man
 IM2 6RB

UKHSA id: 1586477

UKHSA Batch: OCC1901

Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476843	D01 Electrical storage	27/04/2023	29/06/2023	99	110
08476871	G012	27/04/2023	29/06/2023	120	140
08476829	G007	27/04/2023	29/06/2023	120	130
08476848	Storage Underground	27/04/2023	29/06/2023	130	150
08476885	K108B	27/04/2023	29/06/2023	59	68
08476883	K114	27/04/2023	29/06/2023	58	67
08476876	Early Learning	27/04/2023	29/06/2023	37	42
08476870	K101	27/04/2023	29/06/2023	77	90
08476894	K106	27/04/2023	29/06/2023	100	120
08476055	M120	27/04/2023	29/06/2023	60	70
08476093	K104	27/04/2023	29/06/2023	33	38
08476025	M122C	27/04/2023	29/06/2023	40	46
08476027	M130	27/04/2023	29/06/2023	50	58
08476006	L180	27/04/2023	29/06/2023	73	85
08476032	L184	27/04/2023	29/06/2023	91	110
08476005	L190	27/04/2023	29/06/2023	130	150
08476019	A155	27/04/2023	29/06/2023	91	110
08476080	A150	27/04/2023	29/06/2023	79	92
08476059	T275	27/04/2023	29/06/2023	74	86
08476004	T285	27/04/2023	29/06/2023	180	200
08476078	T289	27/04/2023	29/06/2023	110	130
08476056	T296	27/04/2023	29/06/2023	48	55
08476044	T284	27/04/2023	29/06/2023	120	140
08476089	T268	27/04/2023	29/06/2023	190	230
08476075	T274	27/04/2023	29/06/2023	120	140

08476007	Hall	27/04/2023	29/06/2023	51	59
08476029	#2	27/04/2023	29/06/2023	73	85
08476077	Cristorys	27/04/2023	29/06/2023	82	100
08476031	HM132	27/04/2023	29/06/2023	27	32
08476039	HM138	27/04/2023	29/06/2023	41	47
08476046	HM140	27/04/2023	29/06/2023	66	77
08476045	HM155	27/04/2023	29/06/2023	24	28
08476060	HM144	27/04/2023	29/06/2023	57	66
08476079	HM129	27/04/2023	29/06/2023	33	38
08476071	HM102	27/04/2023	29/06/2023	16	19
08476048	WK207	27/04/2023	29/06/2023	72	84
08476076	WK104	27/04/2023	29/06/2023	53	61
08476047	WK103	27/04/2023	29/06/2023	75	87
08476098	WK111	27/04/2023	29/06/2023	300	350
08476042	WK107 Student Common Room	27/04/2023		N/R	N/R
08476061	WK156	27/04/2023	29/06/2023	87	100
08476040	E105	27/04/2023	29/06/2023	160	180
08476034	E104	27/04/2023	29/06/2023	150	170
08476003	TU107	27/04/2023	29/06/2023	32	37
08476035	TU103-A	27/04/2023	29/06/2023	32	37

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Victoria Road School
 Victoria Road
 Castletown, Isle of Man
 IM9 1BA

UKHSA id: 1586498 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476257	Headteachers 137	27/04/2023	31/07/2023	44	60
08476259	Staffroom 141	27/04/2023	31/07/2023	17	23
08476256	Balaglass 156	27/04/2023	31/07/2023	33	45
08476272	Silverdale 121	27/04/2023	31/07/2023	21	28
08476209	South Barrule 113	27/04/2023	31/07/2023	48	66
08476299	Sound 221	27/04/2023	31/07/2023	21	28
08476248	Ayre 222	27/04/2023		N/R	N/R
08476215	Kitchen Office 126/A	27/04/2023	31/07/2023	30	41

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.

Willaston School
 School Road, Willaston
 Douglas, Isle of Man
 IM2 6RD

UKHSA id: 1586478 UKHSA Batch: OCC1901 Client building ref:

Detector Number	Detector Position	Date Issued	Date Returned	As measured Bq m ⁻³	Annual Average Bq m ⁻³
08476096	Headteacher's Room	27/04/2023	24/07/2023	11	16
08476052	Head Of School Room	27/04/2023	24/07/2023	23	32
08476053	Y5 Classroom	27/04/2023	24/07/2023	23	31
08476022	Reception Classroom	27/04/2023	24/07/2023	<10	<10
08476037	Year 3 Wet Area	27/04/2023	24/07/2023	13	17
08476050	Year 1 Classroom	27/04/2023	24/07/2023	10	14
08476069	Year 6 Classroom	27/04/2023	24/07/2023	51	69
08476002	Hall	27/04/2023		N/R	N/R

Regulations

The Ionising Radiations Regulations 2017 (IRR17) apply where there is work in an atmosphere where the radon level is greater than 300 Bq m⁻³ (becquerels per cubic metre of air) as an annual average. Where the IRR17 applies, employers are required to take action to control the resulting exposures. Radon levels in buildings typically follow a clear seasonal pattern (higher in winter, lower in summer), so seasonal correction factors are used to estimate the annual average concentration that indicates whether the Regulations apply.

Advice

Seasonal correction factors are calculated only for the United Kingdom (UK) climate and cannot be applied to measurements in any other country. In addition, we cannot interpret these results with respect to regulations or action levels outside the UK. Please contact the local competent authority for details on the applicable standards.

The above advice applies to these results only.

If you have a Radiation Protection Advisor please ensure you pass these results on to them.

Other comments - if applicable

One or more of the monitors were not returned from this measurement. Radon levels can vary substantially even within the same building so, for re-assurance, you should organise further tests in the locations from which the monitors were not returned.