

Abnormal Operation in accordance with Condition 2.3.20 - 2.3.25 in the period

From 1st January 2021 to 31st March 2021

	Period of Operation (hrs.mins) ^[1]	
	Primary Incinerator	Secondary Incinerator
Operating Condition		
ELV exceeded ^[2]	0 hours 0 minutes	1 hrs 30 mins
CEM out of service ^[3]	0 hours 0 minutes	0 hrs 0 mins
TOTAL this period	0 hours 0 minutes	1 hrs 30 mins
TOTAL year to date ^[4]	0 hours 0 minutes	1 hrs 30 mins

[1] – The period of operation of the incinerator with unburned waste in the combustion chamber when either an emission limit value is being exceeded or a continuous emission monitor is out of service. (See [2] and [3] below.)

[2] – Any periods of operation (see [1] above) when an Emission Limit Value (ELV) in Table 6.1.2 is being exceeded. If such a period exceeds 4 hours (this may be a shorter period for the following parameters: total particulates, CO & TOC) the incineration line must be shutdown and so the only ELVs which can be applicable are those for half-hourly averages. The minimum reportable period is therefore 30 minutes. The reportable period is ended once the shut-down sequence has been commenced and the maximum reportable period for any one event should therefore be 4 hours.

[3] – Any periods of operation (see [1] above) when a Continuous Emissions Monitor (CEM) is out-of-service; excluding periods of less than 90 minutes when the monitor is out-of-service as part of a scheduled calibration or maintenance routine. Periods less than 30 minutes in any one day are not included and the reportable period is ended once the shut-down sequence has been commenced; the maximum reportable period for any one event should therefore be 4 hours.

[4] – If this value is 60 hours or more, then the provisions in conditions 2.3.25a and 2.3.25b allowing operation for up to 4 hours under certain abnormal operating conditions no longer apply.