

Releases into Water from the Licensed Site (Release Point references W2)

Reporting of Monitoring Data for.....February.....(month).....2023.....(year)

Parameter	Emission Point reference W2 Monthly			Emission Point reference W2 Quarterly		
	ELV	No. of measurements	Range of results	ELV	No. of measurements	Range of results
Suspended solids (mg/l) ^[note 1]	-	Not applicable	Not applicable	-		
COD (mg/l) ^[note 1]	-	Not applicable	Not applicable	-		
pH	6 – 10	Continuous	9.06 – 9.63	6 – 10	Continuous	
Temperature Boiler blowdown	30°C			30°C	Not applicable	Not applicable
Ammonia (N)	-	Not applicable	Not applicable	<u>0.6 mg/l</u>		
Visible oil ^[note 1]	Nil	Not applicable	Not applicable	Nil		
Conductivity (µS/cm)	-	Continuous	99.4 – 105.6	-	Not applicable	applicable
Sulphides (mg/l) ^[note 1]	-	Not applicable	Not applicable	-		
Metals (mg/l) ^[note 1]	-	Not applicable	Not applicable	-		
				Emission Point reference W2		
				Duration of flow (h.min) ^[note 2]	669 hours 34 minutes	

Note 1 – Monitoring of suspended solids, COD, visible oil, sulphides and metals in relation to emission point W2 are required to be carried out on a quarterly basis.

Note 2 – The ‘duration of flow’ is the period of time in the reporting period during which surface water overflowed to the river.

Signed:..... 

Date:.....23/3/23.....

..... Authorised to sign on behalf of SUEZ R&R (Isle of Man) Limited - Energy from Waste Facility