

Releases into Water from the Licensed Site (Release Point references W2)

Reporting of Monitoring Data for April 2023

Parameter	Emission Point reference W2 Monthly			Emission Point reference W2 Quarterly		
	ELV	No. of measurements	Range of results	ELV	No. of measurements	Range of results
Suspended solids (mg/l) ^[note 1]	-	Not applicable	Not applicable	-	-	
COD (mg/l) ^[note 1]	-	Not applicable	Not applicable	-	-	
pH	6 – 10	Continuous	6.66 – 9.45	6 – 10	-	
Temperature Boiler blowdown	30°C	No boiler discharge	Not applicable	30°C	Not applicable	Not applicable
Ammonia (N)	-	Not applicable	Not applicable	<u>0.6 mg/l</u>	No boiler discharge	Not applicable
Visible oil ^[note 1]	Nil	Not applicable	Not applicable	Nil	-	
Conductivity (µS/cm)	-	Continuous	69.0 – 647.3	-	Not applicable	applicable
Sulphides (mg/l) ^[note 1]	-	Not applicable	Not applicable	-	-	
Metals (mg/l) ^[note 1]	-	Not applicable	Not applicable	-	-	
				Emission Point reference W2		
				Duration of flow (h.min) ^[note 2]	720hrs 0 mins	

Note 1 – Monitoring of suspended solids, COD, visible oil, sulphides and metals in relation to emission point W2 are required to be carried out on a quarterly basis.

Note 2 – The 'duration of flow' is the period of time in the reporting period during which surface water overflowed to the river.

Signed:..... *R. Weimar*
 Authorised to sign on behalf of SUEZ R&R (Isle of Man) Limited

Form Reference Number: S3/W/1
 Version Number: 8
 Date of Issue: 1st February 2023

Date:.....02/05/23.....